

Model: MHA-V16W/D2N8-B+HB-A160/C****GN8-B

Configure model	
Model name	MHA-V16W/D2N8-B+HB-A160/C****GN8-B
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	16.00 kW
EI input	3.56 kW	5.52 kW
COP	4.50	2.90

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	182 %	133 %
Prated	15.21 kW	13.02 kW
SCOP	4.62	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.45 kW	11.52 kW
COP Tj = -7°C	2.72	1.99
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.57 kW	7.18 kW
COP Tj = +2°C	4.41	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.70 kW	4.68 kW
COP Tj = +7°C	6.56	4.61
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 25 Dec 2021

Pdh Tj = 12°C	3.78 kW	3.32 kW
COP Tj = 12°C	8.51	6.07
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	13.45 kW	11.52 kW
COP Tj = Tbiv	2.72	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.52 kW	10.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.80
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.68 kW	2.67 kW
Annual energy consumption Qhe	6804 kWh	7895 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	249 %	176 %
Prated	13.09 kW	14.17 kW
SCOP	6.33	4.48
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.09 kW	13.38 kW
COP Tj = +2°C	3.35	2.29
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.42 kW	9.11 kW
COP Tj = +7°C	5.36	3.89
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.88 kW	4.06 kW
COP Tj = 12°C	8.11	5.86
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.42 kW	9.11 kW
COP Tj = Tbiv	5.36	3.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.09 kW	13.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

This information was generated by the HP KEYMARK database on 25 Dec 2021

WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.79 kW
Annual energy consumption Qhe	2781 kWh	4231 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	158 %	122 %
Prated	13.76 kW	11.79 kW
SCOP	4.02	3.12
Tbiv	-15 °C	-15 °C

This information was generated by the HP KEYMARK database on 25 Dec 2021

TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.31 kW	7.64 kW
COP Tj = -7°C	3.37	2.65
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.27 kW	4.43 kW
COP Tj = +2°C	4.86	3.79
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.62 kW	2.98 kW
COP Tj = +7°C	6.49	4.81
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.43 kW
COP Tj = 12°C	7.40	6.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.22 kW	9.62 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.89 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.23
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W

This information was generated by the HP KEYMARK database on 25 Dec 2021

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.87 kW	6.57 kW
Annual energy consumption Qhe	8431 kWh	9309 kWh
Pdh Tj = -15°C (if TOL<-20°C)	11.22	9.62
COP Tj = -15°C (if TOL<-20°C)	2.43	1.86
Cdh Tj = -15 °C	0.90	0.90