

This information was generated by the HP KEYMARK database on 15 Oct 2021

[Login](#)

Summary of	COMBO RSJA-16/190	Reg. No.	ICIM-PDC-000036-00
Certificate Holder			
Name	GD Midea Heating & Ventilating Equipment Co., Ltd.		
Address	Penglai Industry Road	Zip	528311
City	Beijiao, Shunde, Foshan	Country	China
Certification Body	ICIM S.p.A.		
Subtype title	COMBO RSJA-16/190		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	1.1 kg		
Certification Date	25.06.2019		

## Model: COMBO RSJA-16/190

<b>Configure model</b>	
Model name	COMBO RSJA-16/190
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	n/a
Any additional heat sources	n/a

<b>General Data</b>	
Power supply	1x230V 50Hz
Off-peak product	No

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 12102-2</b>	
Sound power level indoor	51 dB(A)

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	115 %
COP	2.76
Heating up time	7:01 h:min
Standby power input	26.3 W
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234 l

### Operating test

<b>EN 16147</b>	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed